# Installation Instructions

Adjustable Round Recessed

Plaster Trim

Luminaires must be installed by a qualified electrician. Check with local and national codes for proper installation.

1.5" ProTools

WG-40RPTA

To prevent electrical shock disconnect electrical supply before installation or servicing. Never connect a live fixture!!! Contractor is responsible for adequately reinforcing walls and/or ceilings to support fixture weight. Provide blocking when necessary.

### Step 1 - Confirm Power Supply is Off!

a Unpack luminaire unit. Unit ships with trim, springs, and accessories (e.g. lenses, louvers, etc.) attached as specified. Remote drivers and housings are supplied by Inter-lux.



Plaster Trim Ring

#### Step 2 - Installing Downlight

- a Cut 2-1/8" (54mm) diameter hole
- **b** Detach trim ring from luminaire. To do so, lift trim ring up towards heat sink. Three ball-nose spring plungers that hold luminaire body in place will release with a small tug.
- c Insert trim ring into hole. Use three drywall screws to secure to ceiling.
- **d** Apply joint compound over trim ring. Feather edge flush with rim. Let dry.
- e Insert luminaire into trim ring. Luminaire may need to be rotated so that plungers clear heat sink fins. As luminaire body clears ring, curve insertion path and reflector will click into ring.
  - **Removal:** See next page



### whitegoods

410 381 1497 inter-lux.com answers@inter-lux.com Inter-lux reserves the right to make technical changes without notice.



## Luminaire Removal Instructions

Adjustable

Round Recessed Plaster Trim

Page 2

Luminaires must be installed by a qualified electrician. Check with local and national codes for proper installation.

1.5" ProTools

WG-40RPTA

To prevent electrical shock disconnect electrical supply before installation or servicing. **Never connect a live fixture!!!** 

Contractor is responsible for adequately reinforcing walls and/or ceilings to support fixture weight. Provide blocking when necessary.

Confirm Power Supply is Off!

а

Locate Core Removal Tool, pinch legs together.



Core Removal Tool





Insert into center of luminaire aperture, and release tool, such that legs hook onto inner reflector.

Pull on finger ring. Luminaire core will dislodge from plungers in trim with a firm tug. Take care to rotate luminaire as it is withdrawn such that heat sink and upper half of unit are not damaged.







410 381 1497 inter-lux.com answers@inter-lux.com Inter-lux reserves the right to make technical changes without notice.